

DECEMBER
MIDWAY AIRPORT (MIDNIGHT TO MIDNIGHT)
HEATING AND COOLING CALENDAR DEGREE DAYS

Date	Temperature F.			Daily Heating Degree Days (HDD)		
	Max	Min	Mean	Actual HDD Per Day 2013	5600 HDD Per Day	Variation to 5600 HDD Colder (Warmer)
December 1, 2013	44	30	37	28	28	-
December 2, 2013	43	33	38	27	29	(2)
December 3, 2013	51	37	44	21	29	(8)
December 4, 2013	57	42	50	15	29	(14)
December 5, 2013	42	22	32	33	30	3
December 6, 2013	22	14	18	47	31	16
December 7, 2013	21	9	15	50	31	19
December 8, 2013	26	16	21	44	32	12
December 9, 2013	26	3	15	50	32	18
December 10, 2013	22	1	12	53	32	21
December 11, 2013	21	2	12	53	33	20
December 12, 2013	20	(3)	9	56	33	23
December 13, 2013	31	15	23	42	33	9
December 14, 2013	30	23	27	38	34	4
December 15, 2013	23	12	18	47	34	13
December 16, 2013	22	12	17	48	34	14
December 17, 2013	33	16	25	40	35	5
December 18, 2013	34	16	25	40	35	5
December 19, 2013	43	34	39	26	36	(10)
December 20, 2013	37	34	36	29	36	(7)
December 21, 2013	36	32	34	31	36	(5)
December 22, 2013	35	26	31	34	37	(3)
December 23, 2013	27	-	14	51	37	14
December 24, 2013	19	(1)	9	56	37	19
December 25, 2013	27	19	23	42	38	4
December 26, 2013	36	15	26	39	38	1
December 27, 2013	44	26	35	30	39	(9)
December 28, 2013	51	34	43	22	39	(17)
December 29, 2013	39	12	26	39	39	-
December 30, 2013	15	3	9	56	40	16
December 31, 2013	14	4	9	56	40	16

	Month To Date Heating Degree Days		
December 31, 2013	1,243	1,066	177

	Year To Date Heating Degree Days		
December 31, 2013	6,305	5,600	705

	Season To Date Heating Degree Days		
December 31, 2013	2,437	2,081	356