

DECEMBER
MIDWAY AIRPORT (MIDNIGHT TO MIDNIGHT)
HEATING AND COOLING CALENDAR DEGREE DAYS

Date	Temperature F.			Daily Heating Degree Days (HDD)		
	Max	Min	Mean	Actual HDD Per Day 2015	5600 HDD Per Day	Variation to 5600 HDD Colder (Warmer)
December 1, 2015	45	39	42	23	28	(5)
December 2, 2015	39	33	36	29	29	-
December 3, 2015	37	31	34	31	29	2
December 4, 2015	48	33	41	24	29	(5)
December 5, 2015	45	30	38	27	30	(3)
December 6, 2015	48	32	40	25	31	(6)
December 7, 2015	40	33	37	28	31	(3)
December 8, 2015	49	40	45	20	32	(12)
December 9, 2015	55	43	49	16	32	(16)
December 10, 2015	60	43	52	13	32	(19)
December 11, 2015	55	44	50	15	33	(18)
December 12, 2015	60	51	56	9	33	(24)
December 13, 2015	64	54	59	6	33	(27)
December 14, 2015	62	43	53	12	34	(22)
December 15, 2015	44	41	43	22	34	(12)
December 16, 2015	55	35	45	20	34	(14)
December 17, 2015	36	30	33	32	35	(3)
December 18, 2015	33	26	30	35	35	-
December 19, 2015	32	17	25	40	36	4
December 20, 2015	51	28	40	25	36	(11)
December 21, 2015	54	43	49	16	36	(20)
December 22, 2015	44	37	41	24	37	(13)
December 23, 2015	61	42	52	13	37	(24)
December 24, 2015	44	36	40	25	37	(12)
December 25, 2015	46	36	41	24	38	(14)
December 26, 2015	45	41	43	22	38	(16)
December 27, 2015	43	36	40	25	39	(14)
December 28, 2015	42	32	37	28	39	(11)
December 29, 2015	41	31	36	29	39	(10)
December 30, 2015	31	28	30	35	40	(5)
December 31, 2015	29	24	27	38	40	(2)

Month To Date Heating Degree Days

December 31, 2015	731	1,066	(335)
-------------------	-----	-------	-------

Year To Date Heating Degree Days

December 31, 2015	5,433	5,600	(167)
-------------------	-------	-------	-------

Season To Date Heating Degree Days

December 31, 2015	1,541	2,081	(540)
-------------------	-------	-------	-------